



PRECAUTIONARY DRINKING WATER ADVISORY (Do Not Drink Notice)

**This Notice applies to all residents and users of the Town of Radisson and is effective:
April 9, 2021 at 10:30 am.**

This Do Not Drink Notice is issued due to the water containing very high levels of chlorine and elevated manganese.

A communication (electronic) issue with the raw water supply has resulted in an overfeed of sodium hypochlorite and potassium permanganate to the drinking water supplied by the Town of Radisson. The Water Security Agency and Town of Radisson are advising all consumers to NOT USE THE TAP WATER FOR DRINKING AND COOKING UNTIL FURTHER NOTICE.

Consumers should do the following:

Do Not Drink Your Tap Water – Use Only Bottled Water. Bottled water or other source of known good quality water should be used for all drinking (including baby formula and juice), brushing teeth, washing dishes, making ice and food preparation.

Do Not Try and Treat The Water Yourself. Boiling, freezing, filtering, adding chlorine or other disinfectants, or letting the water stand will not make the water safe.

You will be informed once tests indicate the water is safe for consumption again.

If you require any additional information, please contact the following:

Municipal Office	306-827-2218
Water Security Agency - Saskatoon Office	306-230-3184
Saskatchewan Health Authority – Saskatoon Office	306-655-4605

For media inquiries, please contact comm@wsask.ca and request to speak to a media spokesperson. Please be sure to identify your name, media outlet and contact information.

A handwritten signature in black ink, appearing to read "Bruce Dahl".

Bruce Dahl, B.Sc.
Environmental Project Officer
Water Security Agency